


DETAIL "A"

NOTES:

1. THIS STRUCTURE IS FOR TEMPORARY SERVICE OF SHORT DURATION ONLY, TYPICALLY 6 MONTHS.
2. BASE OF TEMPORARY SERVICE POLE MUST BE A MINIMUM OF 3 FEET FROM FOUNDATION.
3. SREC TO RUN SECONDARY CABLE TO HANDHOLE OR TRANSFORMER.
4. GROUND FAULT PROTECTION SHALL MEET THE NEC 305.
5. ALL WOOD PRODUCTS TO BE PRESSURE TREATED.
6. FOR CUSTOMER/ COMPANY RESPONSIBILITIES SEE COMPANY SPECIFIC SERVICE GUIDE EXHIBIT 19.
7. METER SOCKET MAY BE CONNECTED TO AN EXTERNAL GROUND ROD IF REQUIRED BY LOCAL INSPECTION AUTHORITIES.
8. POLE PLACEMENT TO BE APPROVED BY COMPANY.
9. CALL STATE ONE CALL AGENCY 5 DAYS BEFORE CONSTRUCTION.

<p>SUSSEX RURAL ELECTRIC COOPERATIVE</p>  <p>64 County Route 639 Sussex, New Jersey 07461</p>	<p>TEMPORARY SERVICE UNDERGROUND INSTALLATION</p>	<p>Service Guide</p>	<p>Rev.</p>
		<p>EXHIBIT 2</p>	<p>1</p>
			<p>Date</p>