


**NOTES:**

1. SERVICE DROP CLEARANCES ABOVE GRADE, ALLEYS, DRIVEWAYS, AND AREAS SUBJECT TO TRUCK USE, TO BE IN ACCORDANCE WITH NESC. MINIMUM GROUND CLEARANCE OF 10' TO THE BOTTOM OF THE DRIP LOOP IS REQUIRED PER NEC.
2. TWO BOLTED CONDUIT "U" CLAMPS MUST BE INSTALLED TO BUILDING STUD BY CUSTOMER.
3. IF 30" OR LESS USE MINIMUM OF 2" STEEL CONDUIT, FOR OVER 30" USE MINIMUM 3" STEEL CONDUIT. IF OVER 36" IS REQUIRED FOR GRADE CLEARANCE, GUYING MAY BE REQUIRED BY CUSTOMER PER COMPANY. NO COUPLINGS PERMITTED ABOVE ROOF LINE.
4. METER SOCKET(S) MAY BE CONNECTED TO AN EXTERNAL GROUND ROD, IF REQUIRED BY LOCAL INSPECTION AUTHORITIES.
5. FOR CUSTOMER/COMPANY RESPONSIBILITIES SEE COMPANY SPECIFIC SERVICE GUIDE EXHIBIT 19.

<p>SUSSEX RURAL ELECTRIC COOPERATIVE</p>  <p>64 County Route 639 Sussex, New Jersey 07461</p>	<p><b>OVERHEAD SERVICE RESIDENTIAL MAST INSTALLATION</b></p>	<p><b>Service Guide</b></p>	<p>Rev.</p>
		<p><b>EXHIBIT 4</b></p>	<p>1</p>
			<p>Date</p>