



NOTES:

1. METER SOCKET MAY BE CONNECTED TO AN EXTERNAL GROUND ROD, IF REQUIRED BY LOCAL INSPECTION AUTHORITY.
2. FOR CUSTOMER/COMPANY RESPONSIBILITIES SEE COMPANY SPECIFIC SERVICE GUIDE EXHIBIT 19.
3. CUSTOMER SHALL PROVIDE GROUND MOVEMENT PROTECTION PER NEC 300.5(J) TO PREVENT DAMAGE DUE TO SETTLEMENT OR FROST HEAVES. THE COMPANY RECOMMENDS THE USE OF A SLIP JOINT CONDUIT PRODUCT SUCH AS RIZZCON SAFETY SLIP.

SUSSEX RURAL ELECTRIC COOPERATIVE



64 County Route 639
Sussex, New Jersey 07461

**SINGLE-PHASE UNDERGROUND
SERVICE DIRECT BURIAL**

Service Guide

EXHIBIT 5A

Rev.

1

Date

6/07